

INSTALLATION INSTRUCTIONS



www.csc-led.com

Installation - Surface Mounting

- 1. Do not remove any part of the fixture.
- 2. Please note the specifications on the fixture label.
- 3. Terminal block to be used shall conform to UL standard; and shall be specified as following:
 - the type of terminal: screw;
 - number of terminals: 3 poles;
 - rated voltage: Min. 277V;
 - rated connecting capacity: Min. 18AWG;
 - any necessary preparation of the ends of conductors: the length of exposed ends of conductors shall not be more than 8 mm;
 - any fixing method: fixed inside the connecting box.
- 4. Please note the main specification as following before wiring.
- 5. This product can be installed on the ground.

Warning

- 1. Before starting, please check if the light was damaged during transportation. If any damage is shown, please do not install or use it. Contact your supplier for replacement.
- 2. The product itself and all its components should not be mechanically stressed.
- 3. Installation must not damage or destroy conducting paths or other parts of the product.
- 4. Installation of the LED product (with power supplies) must be made with regard to all applicable electrical and safety standards. Only qualified personnel should perform electrical installation.
- 5. Correct electrical polarity needs to be observed. Wrong polarity may damage or destroy the LED products.
- 6. If fixing on metallic or otherwise conductive surfaces, there should be an electrical insulator between the product and the mounting surface.
- 7. All LEDs are static sensitive. Precautions must be taken to ensure that LEDs are well protected from ESD during handing, even though the chips are safe in low static-electric discharge events.
- 8. DO NOT operate LEDs in reverse bias.
- 9. Damage by corrosion will not be honored as a materials defect claim. It is the user's responsibility to provide suitable protection against corrosive agents such as moisture, condensation and other harmful elements.
- 10. Identify positive (+) and negative (-) outputs of the power supply by using a multimeter.
- 11. Electrical connection should be in a dry area unless adequately sealed.
- 12. This product series emits high light output. DO NOT look directly into the light emitting area. Direct exposure to the light over an extended time period may harm eyes.
- 13. If the external flexible cable or cord of this luminaire is damaged, it shall be exclusively replaced by the manufacturer or his service agent or a similar qualified person in order to avoid a hazard.

1	MIN 105°C SUPPLY CONDUCTORS	LES FILS D'ALIMENTATION 105°C MIN
2	SUITABLE FOR WET LOCATIONS	CONVIENT AUX EMPLACEMENTS MOUILLÉS
3	CAUTION - RISK OF FIRE CAUTION - RISK OF SHOCK	ATTENTION – RISQUE D'INCENDIE ATTENTION – RISQUE DE CHOC
4	THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED	CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS




Correct Disposal of this product
This marking indicates that this product should not be disposed with other household wastes throughout the EU. To prevent possible harm to the environment or human health from uncontrolled waste disposal, recycle it responsibly to promote the sustainable reuse of material resources. To return your used device, please use the return and collection systems or contact the retailer where the product was purchased. They can take this product for environmental safe recycling.

Installation must be carried out by a qualified electrician.


Installation Instructions




- 1. Use a screwdriver to unscrew the lamp screws and remove the upper half of the fixture.




- 2. Unscrew the cover of the entry hole on the lamp base and remove the cover.




- 3. According to the embedded terminal box, punch the corresponding mounting hole on the light's mount.




- 4. Put the input line in the embedded box passes through the waterproof pad and then passes through the lamp base.




- 5. Use screw to lock the lamp base on the embedded junction box.




- 6. Connect the input wire and the dimming wire of the light, then put the connected wires into the embedded terminal box.



- 7. Connect the output wires of driver with the wires of PCB board.



- 8. Use screws to lock the fixture. Installation completed.



Installation must be carried out by a qualified electrician.